

JFW Industries, Inc.



50PA-XXX

***Sample Test Software for Programmable
Attenuator Assemblies***

This document corresponds to firmware 3.0.0 (or higher)

JFW Industries, Inc.

5134 Commerce Square Drive

Indianapolis, IN 46237

Phone: 317-887-1340

sales@jfwindustries.com | www.jfwindustries.com

Table of Contents

Section 1	Introduction	Page
1.1	Ethernet Test Box	3
1.2	Firmware Overview	3
1.3	Attenuator Commands	3
1.4	Security Commands	4
1.5	System Commands.....	4
Section 2	Test Program	5
2.1	Main Menu.....	5
2.2	Network Configuration	6
2.3	RS-232 Configuration	7
2.4	Attenuator Locks.....	8
2.5	Attenuator Blocks	9
2.6	System Commands.....	10
2.7	Keypress.....	11
2.8	Handover.....	12
2.9	Indefinite Handover	13
2.10	Sequential Handover	14
2.11	Script Manager.....	15
2.12	UDP Scan for Systems.....	16

1.0 INTRODUCTION

The sample test program is designed to work with test systems running firmware 3.0.0 (or higher). This test system can be used to configure the Ethernet setting, configure the RS-232 setting, and control programmable attenuators. All transmitted commands are displayed in the *DATA SENT* window. All data received from the test system is displayed in the *DATA RECEIVED* window.

1.1 ETHERNET TEST BOX

JFW does have an Ethernet test box setup at fixed IP address 96.95.94.58 (port 3001). You can connect to this test box with the sample test program and be able to send/receive remote commands.

1.2 FIRMWARE OVERVIEW

Command syntax and examples can be found in the 3.x.x Firmware Manual which is available for download in the test systems section of the JFW website. The 3.x.x firmware is written with a multi-threaded command process that allows multiple connections to the test system. Remote commands received from different connections are handled independently. Each connection can send remote commands to the test system without blocking any functionality of the test system to the other connections. Listed below are some 3.x.x firmware feature highlights:

- DHCP capable.
- Ethernet and RS-232 interfaces run simultaneously.
- Multi-Threaded command process (i.e. non-blocking architecture).
- Up to 12 simultaneous Ethernet connections to the test system.
- User configurable command line prompt.
- Remotely accessible help files with command syntax and examples.
- Command options such as Max dB (-M), Step Size (-S), Lock (-L), Block (-B), and Verbose (-V).
- The ability to escape out of erroneous Pause, Fade, and Handover commands.
- Date feature that allows for time tracking with timestamp command option.
- User comments can now be added to script files without interfering with script execution.

1.3 ATTENUATOR REMOTE COMMANDS

Attenuator Attributes.....	Set the lock/unlocked attributes of an attenuator
Set Attenuator	Set the dB value for an attenuator
Set All Attenuators	Set all attenuators to the same dB value
Read Attenuator	Read the dB setting for an attenuator
Read All Attenuators	Returns the current dB value of all attenuators
Read All Attenuators Extended	Returns the current dB value of all attenuators in table format
Fade Attenuator	Increment the dB setting of an attenuator w/ specified time interval
Variable Attenuator Handover	Can handover up to 8 pairs of attenuators w/ a single command
Block Attributes	Add/remove attenuators from a block and set block attributes
Set Block	Set the dB value for a block
Read Block	Read the dB setting for a block
Read All Blocks.....	Returns the current dB value of all blocks
Fade Block	Increment the dB setting of a block w/ specified time interval
Variable Block Handover	Can handover two blocks of attenuators

1.4 SECURITY REMOTE COMMANDS

IDENTCan be used to set/clear a system password or login to a system if a password is set.
RESTRICTADMIN level user can restrict use of certain remote command (i.e. Date, Prompt)

1.5 SYSTEM REMOTE COMMANDS

IdentificationRespond with system identification information
HelpReturns list of all command available for the test system
SerialSet/respond with serial interface settings baud rate and flow control
NetSet/respond with network interface settings such as IP address, DHCP mode, etc.
CloseCloses all active network connections except for connection that sent command
DateSet/respond with time and date for the system
DisconnectDisconnects the current network connection
UptimeRespond with the time that has passed since being turned on or rebooted
NameSet/respond with name of the current connection
Show UsersReturn a table listing all current connections to the test system
MOTDSet/respond with the message of the day
MessageSent a message up to 480 characters to another connection
PromptSet/respond with the current command prompt setting
PauseSuspend remote command execution for a connection for specified time duration
EscapeBreak from the current task
StoreStores the current settings for all attenuators
RecallRecalls the dB settings saved with Store command and sets all attenuators
RebootRemotely reboot the test system
StartupSetup a list of commands that are executed when the system first boots
WipeClears all saved data and resets the system to factory defaults


2.0 TEST PROGRAM

No installation program needs to be run in order to use the GUI sample test program. Just copy the executable file onto any location on your computer. When you exit the program, it does create some text files that are used to save basic settings for the next session.

2.1 MAIN MENU

The main menu is broken up into seven basic areas.

- In the top right are 3 text boxes that allow the user can change the # of attenuators, the maximum total attenuation, or the attenuation step size.
- The ETHERNET CONNECTION mini-box is where you enter the test system's IP Address and open a new network connection.
- The RS-232 CONNECTION mini-box is where you select your computer's COM port number and your computer's Baud rate.
- The TEST SYSTEM SETUP mini-box is where you set/read the test system's settings. It also has two "query" buttons that allow you to check the test system's network and RS-232 settings.
- The ATTENUATOR COMMANDS mini-box provides all of the functionality you need to set/read attenuator settings.
- Commands sent to the test system are shown in the DATA SENT text box. Messages received from the test system are shown in the DATA RECEIVED text box.
- The bottom right mini-box is additional functionality that is provided by the GUI test program.



2.2 NETWORK CONFIGURATION


Update via RS-232 Connection

Make an RS-232 connection to the test system. A null modem type cable must be used to connect your COM port to the RS-232 port of the test system. Select your COM port number and Baud rate (57600 Baud factory default). Once the RS-232 port is open, click the ETHERNET CONFIGURATION button to open the configuration window. From the configuration window you can query the current settings, change to Fixed Address mode, change the maximum number of network connection, or set the IP Address/Gateway/Net mask. If you use a RS-232 connection you may update multiple network properties without losing your connection.

Update via Ethernet Connection

New test systems are shipped out in DHCP mode. If you connect the test system to your network it will automatically be assigned an IP address, gateway, and net mask from your DHCP server. To determine the current IP address use the UDP SCAN FOR SYSTEMS button located in the TEST SYSTEM SETUP mini-box. Using UDP protocol any JFW test system running firmware 3.0.0 (or higher) will respond with its current settings. Once you know the IP address you may make an Ethernet connection to the test system and use the ETHERNET CONFIGURATION window to configure settings. If you update network properties using a network connection, your network connection will close after each individual change.


All of the functionality of the ETHERNET CONFIGURATION window is derived from the NET remote command. See the Firmware Manual for details/examples of the NET command. Using a terminal program you could set up the network settings typing each NET command out by hand or sending a script.



2.3 RS-232 CONFIGURATION

The RS-232 CONFIGURATION mini-box is located on the SYSTEMS COMMANDS window. You can update the baud rate or hardware flow control setting. The RS-232 settings can be set while you are connected to the test via a RS-232 connection or a network connection.

All of the functionality of the RS-232 CONFIGURATION mini-box is derived from the SERIAL remote command. See the Firmware Manual for details/examples of the SERIAL command. Using a terminal program you could set up the RS-232 settings typing each SERIAL command out by hand or sending a script.




2.4 ATTENUATOR LOCKS WINDOW

To open this window click the LOCKS button located in the TEST SYSTEM SETUP mini-box. Commands sent/received can be viewed in the main window's Data Sent and Data Received text boxes. The attenuator locks window provides the following functionality:

- Lock attenuator(s) to the current connection
- Unlock attenuators for use by all connections
- Steal a locked attenuator from another connection
- Remove an attenuator lock that was set by another connection
- Lock out a manual user (if the test system has a keypad/display)
- Lock block(s) to the current connection
- Unlock blocks for use by all connections
- Steal a locked block from another connection
- Remove a block lock that was set by another connection

All of the functionality of this window is derived from the ATTEN remote command. See the Firmware Manual for details/examples of the ATTEN command. Using a terminal program you could set up the attenuator locks typing each ATTEN command out by hand or sending a script. The syntax of each command as it is sent to the test system can be seen in the "DATA SENT" text box of the main window.



2.5 BLOCKS WINDOW

To open this window click the BLOCKS button located in the TEST SYSTEM SETUP mini-box. Commands sent/received can be viewed in the main window's Data Sent and Data Received text boxes. The blocks window provides the following functionality:

- Add/remove attenuator(s) to a block(s) in the Block Setup mini-box.
- Set minimum/maximum dB limits for a block(s) in the Block Attenuation Boundaries mini-box.
- Set/read block attenuation settings.
- Fade the attenuation of a block.
- Handover operation with two blocks.

All of the functionality of this window is derived from the BLOCK, FADE BLOCK, and VARIABLE BLOCK HANDOVER remote commands. See the Firmware Manual for details/examples of for these commands. The syntax of each command as it is sent to the test system can be seen in the "DATA SENT" text box of the main window.


The screenshot shows the 'Blocks' window with the following sections:

- Block Setup:** Includes 'Add', 'Remove', and 'Clear' buttons. Text fields for 'Block(s): 1' and 'Attenuator(s): 1, 2, 3, 4'.
- Block Attenuation Boundaries:** Includes 'Min' and 'Max' buttons. Text fields for 'Block(s): 1, 2, 3, 4' and 'dB: 95'.
- Block Controls:** Includes 'Set Block' (Block #: 1, at dB: 95), 'Read Block' (Block #: 1, w/ option: Atten List), and 'Read All Blocks' (w/ option: Atten List).
- Fade Block:** Includes 'Fade Block' and 'Escape' buttons. A checked 'with Response' checkbox. Text fields for 'Block #: 1', 'Start at dB: 0', 'End at dB: 95', and 'Interval Time: 500 milliseconds'.
- Handover Blocks:** Includes 'Handover Blocks' and 'Escape' buttons. A checked 'with Response' checkbox. Text fields for 'Block #: 1' (Start at dB: 0), 'Block #: 2' (Start at dB: 95), and 'Interval Time: 500 milliseconds'.

2.6 SYSTEM COMMANDS WINDOW

To open this window click the SYSTEM COMMANDS button located in the TEST SYSTEM SETUP mini-box. All of the functionality of this window is derived from the remote commands that can be found in the System Commands section of the Firmware Manual. Commands sent/received can be viewed in the main window's Data Sent and Data Received text boxes.

Query RS-232 Respond with test systems current RS-232 port settings (i.e. Baud rate, Flow Control)
Query Network..... Respond with test systems current Network settings (i.e. IP Address, Net mask, Gateway, etc.)
Identification..... Respond with system identification information
Store..... Stores the current settings for all attenuators
Recall..... Recalls the dB settings saved with Store command and set all attenuators
Show Users..... Return a table listing all current connections to the test system
Uptime Respond with the time that has passed since being turned on or rebooted
Reboot..... Remotely reboot the test system
MOTD Set/respond with the message of the day
Date..... Set/respond with time and date for the system
Prompt Set/respond with the current command prompt setting
Name..... Set/respond with name of the current connection
Disconnect..... Disconnects the current network connection
Close..... Closes all active network connections except for connection that sent command
Message Sent a message up to 480 characters to another connection
Change Baud Set the baud rate of the test system
Flow Control..... Set the hardware flow control of the test system




2.7 KEYPRESS WINDOW

To open this window click the KEYPRESS button located in the ADDITIONAL GUI FUNCTIONALITY mini-box. All of the functionality of this window is derived from the GUI test program. It sends a set attenuator commands (i.e SA x y<CR>) to the test system when the slider bar location is changed.

Quick Set Attenuator

You can move the slider bar for each attenuator to quick set an attenuator individually. You can slide the slider bar with your mouse or click on the slider bar and use the arrow keys to step forward/backward. The active slider bar is denoted by a box drawn around the entire slider bar.



2.8 HANDOVER WINDOW

To open this window click the HANDOVER button located in the ADDITIONAL GUI FUNCTIONALITY mini-box. All of the functionality of this window is derived from the GUI test program. It streams set attenuator commands (i.e SA x y<CR>) triggered by a timer to achieve the stepping functionality.

Handover Testing

This window can be used to perform handover testing. Set the interval time and click the check boxes to activate each attenuator. Click the START button at the top of the window. Each slider bar will begin moving and sending remote commands to the test system. The current attenuation setting of each attenuator is listed and updated as the attenuation changes. When the attenuation level reaches the “Stop at dB” value, the slider bar will stop moving.

Manual Handover Testing

Use the plus/minus buttons to manually keypress through a handover test. Click the checkboxes to active which attenuators you wish to manually step.

Quick Set Attenuator

You can move the slider bar for each attenuator to quick set an attenuator individually. You can slide the slider bar with your mouse or click on the slider bar and use the arrow keys to step forward/backward.

The screenshot shows the 'GUI Handover' window. At the top, it has a title bar and a description: 'This window can be used to perform handover tests. The handover ends when the attenuation reaches the stop value that is user defined.' Below this are two main sections: 'Keypress Handover' with '+' and '-' buttons, and 'Automated Handover' with a 'Start' button, an 'Interval Time (mS): 500' input field, and a 'Reset' button. Below these are eight rows of controls for individual attenuators. Each row includes a checkbox, a slider bar (0dB to 95dB), an 'Attenuator #' input field, a 'Start at dB:' input field, a 'dB Step Size:' input field, and a 'Stop at dB:' input field. The first two rows have their checkboxes checked, while the others are unchecked.

Attenuator #	Start at dB	dB Step Size	Stop at dB
1	0	1	95
2	0	1	95
3	0	1	95
4	0	1	95
5	0	1	95
6	0	1	95
7	0	1	95
8	0	1	95

2.9 INDEFINITE HANDOVER WINDOW

To open this window click the INDEFINITE HANDOVER button located in the ADDITIONAL GUI FUNCTIONALITY mini-box. All of the functionality of this window is derived from the GUI test program. It streams set attenuator commands (i.e SA x y<CR>) triggered by a timer to achieve the stepping functionality.

Functionality

This window functions just like the HANDOVER window except that it does not stop stepping when it reaches the user specified stop dB value. When it reaches the stop dB value, it begins stepping in the opposite direction. It does not stop oscillating between the start/stop attenuation values until the user pauses or resets the operation.

Manual Handover Testing

Use the NEXT button to manually keypress through a handover test. Click the checkboxes to active which attenuators you wish to manually step.

Quick Set Attenuator

You can move the slider bar for each attenuator to quick set an attenuator individually. You can slide the slider bar with your mouse or click on the slider bar and use the arrow keys to step forward/backward.

GUI Indefinite Handover

This window can be used to perform indefinite handover tests. The handover will continue indefinitely until the user ends the test.

Keypress Handover **Automated Handover**

Next Start Interval Time (mS): 500 Reset

Minimum Interval Times

Select Atten # (1 - 8)	Slider (0dB to 95dB)	Attenuator #	Start at dB	dB Step Size	Stop at dB
<input checked="" type="checkbox"/>		1	0	1	95
<input type="checkbox"/>		2	0	1	95
<input type="checkbox"/>		3	0	1	95
<input type="checkbox"/>		4	0	1	95
<input type="checkbox"/>		5	0	1	95
<input type="checkbox"/>		6	0	1	95
<input type="checkbox"/>		7	0	1	95
<input type="checkbox"/>		8	0	1	95

2.10 SEQUENTIAL HANDOVER WINDOW

To open this window click the SEQUENTIAL HANDOVER button located in the ADDITIONAL GUI FUNCTIONALITY mini-box. After changing settings, you must click the RESET button for the window to operate properly. The RESET button resets the slider bars to their proper starting position.

“Reset & Repeat”

When it reaches the final dB setting of the final attenuator, it will restart the entire sequence from the beginning.

“Reverse from Last”

When it reaches the last dB setting of the last attenuator, it steps back through the entire sequence in reverse order starting with the last attenuator listed (i.e. bottom slider bar).

“Reverse from First”

When it reaches the last dB setting of the last attenuator, it steps back through the entire sequence in reverse order starting with the first attenuator listed (i.e. top slider bar).

“Stop”

When it reaches the last dB setting of the last attenuator, it stops.

“Dual Handover w/ Pause”

This option requires a minimum of 3 attenuators. It activates two slider bars at a time (i.e. two attenuators). It performs a 2 attenuator handover. The first pair of attenuators will be to top two slider bars. The last pair of attenuator will be the bottom slider bar and the top slider bar. The entire sequence will repeat after the specified pause duration.

Attenuator #	Start at dB	Stop at dB
1	0	95
2	0	95
3	0	95
4	0	95
5	0	95
6	0	95
7	0	95
8	0	95

2.11 SCRIPT MANAGEMENT WINDOW

The Script Management screen allows you to send long complicated scripts to the test system from the test program. You can write your own script in a text editor or directly into the “Script to Send” text box. Traditionally, if you were sending a script through a Telnet service like PuTTY, it sends the entire script all at once. If the script is very long, this could overflow the receive buffer of the test system which would cause the test system to crash, reboot or lockup. Since many of these kinds of long scripts are repetitive, the Script Management window allows a user to send a smaller script repetitively and control the time duration between the scripts.

Saving and Loading Scripts

The Script Management window allows you to save your custom scripts as .jfw (.txt) files. The file will contain all of the information in Script Manager including the Description, Number of times to Send, Pause Duration between Scripts, the Initializing Script, and the Main Script.

Recording Scripts

Recording a script is helpful if you cannot remember the exact command format for a particular command and also eliminates typing errors from entering them manually. By selecting the “Record Script” checkbox, all commands sent from the rest of the test program will NOT be sent to the test system but will instead be recorded in the “Script to Send” text box.

Calculate Script Duration

This feature calculates the entire length of the script in the “Script to Send” text box in milliseconds. This accounts for 3 milliseconds of processing time for each command. Commands that execute over time such as Pause, Fade, and Variable Handover are also included in the calculation.

The screenshot shows the 'Script Management' window with the following components:


- Left Panel:**
 - Load Script / Save Script:** Includes fields for 'Script Filename: test 1.jfw' and 'Script Description: fade, pause, fade, read'.
 - Send Script:** Features a 'Send Script' button, a 'Times' input set to 1, and checkboxes for 'Indefinitely' and 'Stop Sending' (which is selected).
 - Once Every:** Set to 1000 mS, with an 'Automatically Update' checkbox.
 - Record Script:** A checkbox that is currently unchecked. A note states: 'If checked, any sent commands from the main interface will automatically be added to the script window.'
 - Calculate Script Duration:** Shows an estimate of 195012 mS, with buttons for 'Use This Duration' and a summary of '4 Total Commands' and '36 Total Characters'.
- Center Panel:**
 - Script To Send Once At Start:** An empty text box.
 - Script To Send 1 Times:** Set to 'Every 1000 milliseconds'. The script content is:

```
FA 1 0 95 1S
PAUSE 5S
FA 1 95 0 1S
RA 1
```
 - A 'Clear Text' button is at the bottom.
- Right Panel:**
 - Data Received:** A text box showing received data:

```
Fade Started
Fade Finished
Pausing for 5S
Pause complete
Fade Started
Fade Finished
Atten #1 = 0dB
```
 - A 'Disable' checkbox is at the top right.
 - Buttons for 'Clear Text' and 'Save Received Data to .txt File' are at the bottom.

2.12 UDP SCAN FOR SYSTEMS

To open this window click the UDP SCAN FOR SYSTEMS button located in the TEST SYSTEM SETUP mini-box. This window is helpful when you first receive a test system and the test system does not have a front panel display showing the current IP address or baud rate. Just click the SCAN button and any JFW test system on your network running firmware 3.0.0 (or higher) will respond with its model number, serial number, and port configuration settings. The request and responses are sent via UDP protocol. If you have multiple test systems with the same model number, then use the serial number as their unique identifier.



Each line shows the current settings for a test system on your network.